



Product Service

CERTIFICATE

No. Z2 121422 0003 Rev. 00

Holder of Certificate: **JUST SOLAR GROUP LIMITED**

No.66 Miaoqing Road, Minhang District
201706 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262507401-00

Valid until: 2029-04-22

Date, 2025-03-10

(Zhulin Zhang)



CERTIFICATE

No. Z2 121422 0003 Rev. 00

Model(s): JST-FCMH-xxxW-HD, xxx=670 to 730, in steps of 5,
 JST-FDMH-xxxW-HD, xxx=610 to 665, in steps of 5,
 JST-FEMH-xxxW-HD, xxx=560 to 610, in steps of 5,
 JST-FGMH-xxxW-HD, xxx=510 to 555, in steps of 5,
 JST-FIMH-xxxW-HD, xxx=455 to 500, in steps of 5,
 JST-FKMH-xxxW-HD, xxx=405 to 445, in steps of 5,
 JST-FFMH-xxxW-HD, xxx=550 to 600, in steps of 5,
 JST-FHMH-xxxW-HD, xxx=490 to 530, in steps of 5,
 xxx is standing for rated output power at STC

Parameters:	Construction:	Framed with Junction box, Cable and Connectors.
	Safety Class:	Class II
	Maximum System Voltage:	1500 V DC
	Fire Safety Class:	Class C according to UL790.
	Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China

Tested according to: IEC 61215-1:2021
 IEC 61215-1-1:2021
 IEC 61215-2:2021
 IEC 61730-1:2023
 IEC 61730-2:2023